© 1989 IEEE. Personal use of this material is permitted. However, permission to reprint/republish this material for advertising or promotional purposes or for creating new collective works for resale or redistribution to servers or lists, or to reuse any copyrighted component of this work in other works must be obtained from the IEEE.

DEVELOPMENT OF A NEW IHQ LINAC (CONSTRUCTION AND ACCELERATION OF 2MeV PROTOTYPE LINAC)

T.Hattori, H.Muto, H.Suzuki^{*}, T.Fukushima^{**} and N.Ueda^{**}

Research Laboratory for Nuclear Reactors, Tokyo Institute of Technology Ohokayama, Meguro-ku, Tokyo 152, Japan.

* National Institute of Radiological Sciences, Anagawa, Chiba-shi, Chiba-ken, 260, Japan.

****** Institute for Nuclear Study,University of Tokyo,Midori-cho,Tanashi-shi,Tokyo,188,Japan.

Abstract

Characteristics of an interdigital-H type linac structure with focusing finger electrodes (IHQ) have been studied. A prototype IHQ linac was designed to accelerate proton from 0.8 to 2.0MeV with an operation frequency of 101.5MHz. The geometrical dimension of the linac tank is 54cm in inner diameter and 92cm in length. The linac has been constructed and has successfully accelerated beams.¹⁻⁶

Introduction

In this structure design, the RF fields is used for focusing of ions as well as for acceleration. The resent success of RFQ linacs which use the RF electric field not only acceleration but also for focusing has solved most problems associated with the acceleration of intense low velocity ions.

On the other hand, idea of spatially uniform acceleration and focusing scheme of Kapchinsky and Teplyakov⁶ who have proposed the basic idea of RFQ linac is known to be applicable only to the low energy region of 2MeV or less, because of its low effective shunt impedance. Boussard tried an RF acceleration and focusing by attaching circular fingers to the face of drift tubes⁷. A similar configuration was proposed by R.W.Müller for his split coaxial structure⁸.

We have begun to study an interdigital-H type linac structure with Boussard's electrode configuration as shown in Fig. 1. The IH type structure is well known for its high shunt impedance at low and medium particle velocity⁹. This type linac has a high effective shunt impedance and is applicable to the medium energy region.



Fig.1 Photograph of 1/2 scale IHQ model resonator

Basic Model Experiment

A magnetic analogue one acceleration cell as well as RF models have been constructed to study accelerating and focusing. In our structure, the electromagnetic field is expected to have complicated form. A detailed study of the behavior of the field components (as a function of a radial, azimuthal and longitudinal coordinates) is necessary. When use RF models, it is difficult to separate the field into three dimensional components.

The analogue model provides a better solution. The multipole and gap field distribution have been measured by using a Hall probe and a rotating coil. The multipole components higher than quadrupole are smaller than several % of the quadrupole component. Results of the basic RF model and the magnetic analogue model measurements were used for the numerical calculation of beam orbit.

2MeV Proton Linac

Based on successful results of the low level RF measurements and numerical calculation of the beam orbit, a prototype IHQ linac is constructed in order to demonstrate the operational capabilities of the new structure.

For the design work of the cavity, a 1/2 scale model resonator was made of brass as shown in Fig. 1. The resonance frequency and the field distribution were checked by measurements on the model in term of the end cut of the ridge.

The particle trajectory was analyzed by mean of a modified computer program (LINOR)¹⁰ in which the most important input data were obtained from the model experiments. Calculated results of the phase, energy and radial profiles are shown in Fig. 2.

Table

Parameters of Prototype IHQ Linac

| Acceleration Particle | Proton |
|--------------------------|-----------------|
| Energy Input | 0.8 MeV |
| Output | 2.0 Mev |
| Operation Frequency | 101.5 MHz |
| Synchronous Phase | - 30° |
| RF Power | 16 kW |
| Number of Cell | 10 |
| Focusing Sequence | F D |
| Element | RFQ with Finger |
| Drift Tube Bore Diameter | 16 mm |
| Outer Diameter | 48 mm |
| Stem Diameter | 24 mm |
| Gap Distance | 40 mm |
| Voltage | 145 kV |
| Tank Inner Diameter | 54 cm |
| Length | 92 cm |
| Ridge Width | 6.4 cm |
| Length | 72 cm |
| Height | 27 cm |
| Vacuum System | 520 1/s TMP |

The main parameters of the prototype IHQ linac are summarized in table. The linac designed to accelerate protons from 0.8 to 2.0MeV with an operating frequency of 101.5MHz. The geometrical dimension of the linac tank is 54cm in inner diameter and 92cm in length. The voltage distribution of the 1/2 scale model and the prototype linac are shown in Fig. 3



Fig. 2 Phase, Energy and Radial Profiles of IHQ Linac



Fig. 3 Voltage distribution of 1/2 scale model and prototype linac

Acceleration Test Stand

A beam acceleration test stand was constructed at INS¹¹. The injection is the RFQ linac "TALL"¹² which has capability accelerating up to 0.8MeV/u. The accelerated protons up to 2MeV are analyzed with an analyzer magnet having a bending angle of 90" and a momentum dispersion of 160cm. Slit systems, multiwire profile monitors and Faraday cups are placed at the object and image points of the magnet. A photograph of constructed IHQ linac and its beam acceleration test stand are shown in Fig.4.



Fig. 4 Photograph of constructed 2MeV IHQ linac and beam acceleration test stand



Fig. 5 Intensity of 2MeV proton vs RF power

Acceleration Test

A beam acceleration test was performed under pulse operation of two linacs having automatic tuning systems with a duty factor of 5%. The pulse width and repetition period were 1ms and 20ms, respectively. Beam tests have been performed proton from an ECR ion source. The intensity of 2MeV proton is shown in Fig.5 as a function of the RF power. The momentum distribution of accelerated particles were measured as a function of the RF power as shown in Fig. 6. The acceleration characteristics agree well with computer simulation. The effective shunt



Fig. 6 Energy distribution of output proton vs RF power

impedance of the IHQ linac was estimated to be about 132MΩ/m from RF power for proton.

Acknowledgment

The authors thank the member of the Accelerator Research Division at INS for useful discussion and their helps. They thank people of the machine shop at INS and Japan Steel Works, Handa-Sangyou, Asahi-Kent Yuukousha and Toshiba Corporation who manufactured skillfully the prototype IHQ linac and acceleration test stand.

References

- T. Hattori, H. Suzuki and H. Kinoshita; Proc. Meeting on Linear Accelerator, 10, 102 (1985)
- [2] T. Hattori, H. Suzuki, H. Kinoshita and S. Kamohara; Proc. Meeting on Linear Accelerator, 11, 116(1986)
- [3] T. Hattori, H. Suzuki and T. Fukushima; Proc. of the 6th. Symp. on Accelerator Science and Technology, 6, 101 (1987)
- [4] T.Hattori, H.Suzuki and T.Fukushima; Proc. Meeting on Linear Accelerator, 12, 101 (1987)
 [5] T.Hattori, H.Suzuki, H.Muto, T.Fukushima and
- [5] T.Hattori, H.Suzuki, H.Muto, T.Fukushima and N.Ueda; Proc. Meeting on Linear Accelerator, 13, 77 (1988)
- [6] I. M. Kapchinsky and V. A. Teplyakov; Prib. Tekh. Eksp., No2, 19 (1970)
- [7] Boussard ; IEEE Tran. NS-12, 648 (1965)
- [8] R.W.Müller ; GSI-Report 79-7 May 1979
- [9] T. Hattori, K. Sato, H. Suzuki, Y. Oguri and E. Arai; Proc. 1986 Intn. Conf. of Linear Accelerator, p. 337 (1986)
- [10] A.Goto et al. ; Proc. Comp. Acc. Des. and Opera. p. 539 (1983)
- [11] N. Ueda, T. Nakanishi, S. Arai, T. Hattori, T. Fukushima, Y. Sakurada, T. Honma, N. Tokuda, S. Yamada, M. Takanaka, A. Itano, A. Mizobuchi and Y. Hirao; IEEE Tran. NS-30, 2975 (1983)
- [12] N. Ueda, A. Mizobuchi, T. Nakanishi, S. Yamada, N. Tokuda and Y. Hirao; IEEE Tran. NS-32, 3178 (1985)

946